


# EVAPCO, INC.



|      |               |         |              |       |     |        |                 |      |  |      |           |          |  |
|------|---------------|---------|--------------|-------|-----|--------|-----------------|------|--|------|-----------|----------|--|
| UNIT | COOLING TOWER | MODEL # | LRWB 3-2E6-Z | SCALE | NTS | DWG. # | RP171248-MRA-LF | REV. |  | DATE | 5/15/2024 | SERIAL # |  |
|------|---------------|---------|--------------|-------|-----|--------|-----------------|------|--|------|-----------|----------|--|

## NOTES:

1. (M) - FAN MOTOR LOCATION
2. HEAVIEST SECTION IS LOWER SECTION
3. MPT DENOTES MALE PIPE THREAD  
FPT DENOTES FEMALE PIPE THREAD  
BFW DENOTES BEVELED FOR WELDING
4. + UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE SEPARATE DRAWINGS FOR ACCESSORIES)
5. 19mm DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING
6. MAKE-UP WATER PRESSURE-137 kPa MIN, 344 kPa MAX
7. PAN EQUALIZER SUPPLIED BY EVAPCO AND SHIPPED LOOSE FOR FIELD INSTALLATION BY OTHERS



|                 |      |      |                  |      |    |                         |      |    |                          |   |
|-----------------|------|------|------------------|------|----|-------------------------|------|----|--------------------------|---|
| SHIPPING WEIGHT | 5405 | kg + | OPERATING WEIGHT | 8905 | kg | HEAVIEST SECTION WEIGHT | 1460 | kg | NO. OF SHIPPING SECTIONS | 4 |
|-----------------|------|------|------------------|------|----|-------------------------|------|----|--------------------------|---|