


# EVAPCO, INC.



|      |               |         |         |       |     |        |                 |      |  |      |          |          |  |
|------|---------------|---------|---------|-------|-----|--------|-----------------|------|--|------|----------|----------|--|
| UNIT | COOLING TOWER | MODEL # | LPT-316 | SCALE | NTS | DWG. # | RP171248-ERA-LF | REV. |  | DATE | 5/1/2024 | SERIAL # |  |
|------|---------------|---------|---------|-------|-----|--------|-----------------|------|--|------|----------|----------|--|

## NOTES:

1. (M)- FAN MOTOR LOCATION
2. HEAVIEST SECTION IS LOWER SECTION
3. MPT DENOTES MALE PIPE THREAD  
FPT DENOTES FEMALE PIPE THREAD  
BFW DENOTES BEVELED FOR WELDING
4. + UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE SEPARATE DRAWINGS FOR ACCESSORIES)
5. 3/4" DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING
6. MAKE-UP WATER PRESSURE-20 psi MIN, 50 psi MAX
7. PAN EQUALIZER SUPPLIED BY EVAPCO AND SHIPPED LOOSE FOR FIELD INSTALLATION BY OTHERS



|                 |       |        |                  |       |      |                         |      |      |                          |   |
|-----------------|-------|--------|------------------|-------|------|-------------------------|------|------|--------------------------|---|
| SHIPPING WEIGHT | 11900 | lbs. + | OPERATING WEIGHT | 19620 | lbs. | HEAVIEST SECTION WEIGHT | 3220 | lbs. | NO. OF SHIPPING SECTIONS | 4 |
|-----------------|-------|--------|------------------|-------|------|-------------------------|------|------|--------------------------|---|