UNIT	COOLING TOWER	
MODEL #	AT 112-2K12	SCALE NTS

EVAPCO, INC. Evapeo



DWG. # REV. T3121224-DRD-ST DATE 5/3/2024 SERIAL #

## NOTES:

- 1. (M)- FAN MOTOR LOCATION
- 2. HEAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT
- 7. DIMENSIONS LISTED AS FOLLOWS: **ENGLISH FT-IN** [METRIC] [mm]


## **FACE C**


**FACE B PLAN VIEW** 



**FACE D** 

**FACE A** 





DRAWN BY: KDS NO. OF SHIPPING SECTIONS **SHIPPING** OPERATING HEAVIEST SECTION 7450 lbs+ [3380] kg+ 13660 lbs+ [6200] kg+ 5050 lbs+ [2295] kg+ WEIGHT WEIGHT WEIGHT